



TEST REPORT

FORMAT NO. ENV/FM/55

Name of the Client	: SAHARAI SETU DHABA	Type of Industry	: NA
Address	: VILL. + PARA- KENDRADANGAL, P.S.- PANRUI, P.O.-SATTORE, MOUZA-57, DAG-678, DIST.-BIRBHUM, PIN-731236	Sampling Date	: 12.09.2026
		Receiving Date	: 12.09.2026
		Date(s) of Analysis	: 12.09.2026-13.09.2026
		Date of Issue	: 19.09.2026
Sampling Plan & Procedure	: ENV/SOP/01/05	Deviation from the Sampling Method and Plan	: No
		Type of Sample	: Drinking Water
Location	: Bore Well	Sample Condition	: Sealed
		Testing Location	: Permanent Testing
Sample ID	: ENV/KOL/W/4261	ULR No. (Report ID)	: TC6014260000004261F

- Sample Collected By: Sadhan Layek

MICROBIOLOGICAL TEST FINDINGS :					
Sl. No.	Test Parameters	Test Method	Unit	Result	Norms as per IS 10500 : 2012
01.	Total Coliform	IS 15185	cfu/100 ml	<1.0	Not Detectable
02.	E. Coli	IS 15185	cfu/100ml	<1.0	Not Detectable

Remarks:. The Sample is Satisfactory as per IS 10500 : 2012 for the above mentioned parameters.

- Note:
- a) CFU indicates Colony Forming Unit.
 - b) <1.0 indicates "Absent", No Colony Developed i.e. No Coliform Found.
 - c) Sample Collected By Envirocheck & sent to Lab in sealed condition.
 - d) Result relates only to the sample tested.

... End of the test Report ...

Reviewed By

PRIYANKA MUKHERJEE
Technical Manager, Microbiology

Approved By

Dr. AJOY PAUL
Quality Manager





TEST REPORT

FORMAT NO. ENV/FM/55

Name of the Client	:	SAHARAI SETU DHABA				Type of Industry	:	NA			
Address	:	VILL. + PARA- KENDRADANGAL, P.S.- PANRUI, P.O.-SATTORE, MOUZA-57, DAG-678, DIST.-BIRBHUM, PIN-731236				Sampling Date	:	12.09.2026			
						Receiving Date	:	12.09.2026			
						Date(s) of Analysis	:	12.09.2026-19.09.2026			
						Date of Issue	:	19.09.2026			
Sampling Plan & Procedure	:	ENV/SOP/01/04	Deviation from the Sampling Method and Plan			:	No	Type of Sample	:	Drinking Water	
Location	:	Bore Well	Sample Condition	:	Sealed	Testing Location	:	Permanent Testing			
Sample ID	:	ENV/KOL/W/4261			ULR No. (Report ID)		:	TC6014260000004261F			

CHEMICAL TEST FINDINGS :						
Sl. No.	Test Parameters	Test Method	Unit	Result	Norms as per IS 10500 : 2012	
					AL	PL
01.	Turbidity	IS 3025(Part 10)	NTU	1.20	1.0	5.0
02.	pH at 25°C	IS 3025(Part 11)	-	7.26	6.5 - 8.5	No Relaxation
03.	Total Hardness as CaCO ₃	IS 3025(Part 21)	mg/l	140.0	200	600
04.	Total Dissolved Solids	IS 3025(Part 16)	mg/l	358.0	500	2000
05.	Iron as Fe	IS 3025 (Part 53)	mg/l	0.48	1.0*	No Relaxation
06.	Calcium as Ca	IS 3025(Part 40)	mg/l	41.60	75	200
07.	Magnesium as Mg	IS 3025(Part 46)	mg/l	8.64	30	100
08.	Total Alkalinity as CaCO ₃	IS 3025 (Part 23)	mg/l	170.0	200.0	600.0
09.	Fluoride as F	IS 3025 (Part 60)	mg/l	<0.1	1.0	1.5

Remarks: The Sample is Satisfactory as per IS 10500 : 2012 for the above mentioned parameters.

Note: 1. AL - Acceptable Limit 2. PL - Permissible Limit

a) N.A. means Not Available.

b) The (*) marked limit is as per IS: 10500-2012 - Drinking Water Specification (Amendment No.1, June'2015).

c) Result relates only to the sample tested.

d) Sample Collected By Envirocheck & sent to Lab in sealed condition.

... End of the test Report ...

Reviewed By

DURBADAL CHAKRABORTY
Dy. Quality Manager



Approved By

DR. AJAY PAUL
Quality Manager